



### Inspection Report

Morehouse School Of Medicine  
720 Westview Drive Sw  
Atlanta, GA 30310

Customer ID: **883**

Certificate: **57-R-0124**

Site: 001

MOREHOUSE SCHOOL OF MEDICINE

Type: ROUTINE INSPECTION

Date: 13-FEB-2018

**3.25(c) REPEAT**

**FACILITIES, GENERAL.**

\*\*\*There is an ongoing occurrence of standing water in the storage rm B-55. Supplies of caging, enrichment materials, water bottles, etc. are kept in the room. The water is coming in from the outside of the building and entering through the wall during inclement weather. Most of the supplies have been placed on racks or platforms to minimize exposure to contamination but without knowing where the water is coming in there is still potential for contamination. The leakage shall be repaired and/or items shall not be stored at this location to protect them from contamination.

This inspection and exit interview were conducted with the Director of Operations.

Prepared By:

**WILLIAMS MICHELLE, D V M**

WILLIAMS MICHELLE, D V M USDA, APHIS, Animal Care

Date:

13-FEB-2018

Title:

VETERINARY MEDICAL OFFICER 2028

Received By:

Title:

Date:

13-FEB-2018